

Certificate of Compliance

Certificate Number **20090624-R25976**
Report Reference **R25976, 2009 March 29**
Issue Date **2009 June 24**

Page 1 of 1



Issued to: **ROLLC FACTORY**

Al Manak Industrial Area
Al Kharg Rd, Po Box 63975
Riyadh 11526 Saudi Arabia

*This is to certify that
representative samples of*

ROLLING STEEL FIRE DOORS
Oversized rolling steel fire door assemblies


*Have been investigated by Underwriters Laboratories Inc.® in
accordance with the Standard(s) indicated on this Certificate.*

Standard(s) for Safety: The basic standard used to investigate products in this category is ANSI/UL 10B,
"Fire Tests of Door Assemblies."

Additional Information: The maximum size of the oversized door for standard fire protection provided
with the Oversize Door Certificate or Label shall not exceed 7.31 m (24 ft) in
width (edge of guide to edge of guide) and 7.31 m (24 ft) in height (floor to
underside of door bracket).

Look for the UL Classification Mark on the product

Only those products bearing the UL Classification Mark should be considered as being covered by UL's Classification and Follow-Up Service.

The UL Classification Mark includes: UL in a circle symbol:  with the word "CLASSIFIED" (as shown); a control number (may be alphanumeric) assigned by UL; a statement to indicate the extent of UL's evaluation of the product; and, the product category name (product identity) as indicated in the appropriate UL Directory.

Issued by: *Ranjini S*

Reviewed by: *Alec Hauser*

Ranjini S, Customer Service Professional.

Alec Hauser, Staff Engineer, Fire Protection Division

UL India Pvt. Ltd

Underwriters Laboratories Inc.

Any information and documentation provided to you involving UL Mark services are provided on behalf of Underwriters Laboratories Inc..
For questions in India, you may call 91-80-4138 4400, UL India pvt. Ltd